



1783

**DECLARATION OF PERFORMANCE****1. DOP NUMBER:** MK710**2. PRODUCT NAME & TYPE:** LIHCH FE 180 PH 120**3. INTENDEN USE/S:**

These cables are used indoor fire alarm systems that transmits the signal and data between control panels , detectors , buttons and area control modules.

**4. MANUFACTURER:**

Mekas Kablo Sanayi ve Ticaret A.Ş. Kocaeli Kobi OSB 6. Cad. No:14/1 41455 Dilovası-KOCAELİ

**5. AUTHORIZED REPRESENTATIVE:** NO**6. SYSTEM OF ASSESSMENT AND VERIFICATION OF CONSTANCY OF PERFORMANCE ( AVCP ):**

System 3

**7. NOTIFICATION BODY / REPORT NO:**

1783 TURKISH STANDARDS INSTITUTION ( +90 262 723 15 26 ) /44980/02-23

**8. DECLARED PERFORMANCES:**

Essential Characteristics	Performance	Harmonized Technical Standards
Reaction to Fire	Eca	EN 50575:2014+A1:2016
Dangerous Substances	None	

**9.** The performance of the product defined is in conformity with the set of declared performances. This declaration of performance is issued under the sole responsibility of the manufacturer identified above. Signed for and in name of the manufacturer by in point 4:

Signed for on behalf of the manufacturer by:

Name and function  
General Manager  
İbrahim KAYA

Date  
14.02.2023

Signature

